

Continued From Sheet No. E-5.00

## **E2. Records, accounting, and control. (Contd)**

On **EBB**, the customer or designated representative is to input the delivery point on Michigan Gas Utilities system, the pipeline (shipper's) name and contract number, and the delivered volume of gas it desires the Company to receive on the customer's behalf during the month. The Company will also make Critical Day and other important operational notices that may affect nominations available via **EBB**. If circumstances arise whereby **EBB** is not available, the Company will use a paper-based nominations process until **EBB** is back on-line. The customer and the Company shall inform each other of any changes in anticipated deliveries immediately. Changes in monthly and daily nominations may be necessary to accommodate certain operating conditions such as the implementation of an Operational Flow Order (OFO) by the Company pursuant to Rule C3.2(c) on Sheet Nos. C-10.00 through C-14.00 and for monthly load balancing purposes as described on Sheet Nos. E-14.00 through E-17.00.

## **E3. GAS QUALITY**

- (a) The quality of gas delivered to the Company shall meet the following requirements:
  - (i) Gas shall not contain more than three percent oxygen by volume;
  - (ii) Gas shall be commercially free from objectionable odors, solid or liquid matter, dust, gum or gum-forming constituents that might interfere with its merchantability or cause injury to or interference with proper operation of the lines, regulators, meters, or other appliances through which it flows;
  - (iii) Gas shall not contain more than 0.3 grain of hydrogen sulphide per 100 cubic feet;
  - (iv) Gas shall not contain more than twenty grains of total sulfur (including hydrogen sulfide and mercaptan sulfur) per 100 cubic feet;
  - (v) Gas shall not at any time have a carbon dioxide content in excess of two percent by volume;
  - (vi) Gas shall not contain an amount of moisture which at any time exceeds seven pounds per million cubic feet; and

Continued on Sheet No. E-7.00

Issued: **November 17, 2021**  
By: **Theodore Eidukas**  
VP Regulatory Affairs  
Milwaukee, Wisconsin

Effective for Service  
On and After: **January 1, 2022**  
Issued Under Authority of  
Michigan Public Service Commission  
Dated: **September 9, 2021**  
In Case No: **U-20718**

Continued From Sheet No. E-6.00

**E3. Gas quality. (Contd)**

- (vii) Gas shall not contain a nitrogen content in excess of three percent by volume.
- (b) Gas delivered to the Company shall have a total heating value per cubic foot of not less than 950 British thermal unit (BTUs) nor more than 1,100 BTUs.

**E4. SERVICE REQUIREMENTS**

(a) Quantities

- (i) The customer may deliver or cause to be delivered and the Company will accept quantities of gas up to the MDQ agreed to in the contract with the customer. Such deliveries shall be made to the Company at a location(s) agreed to by the Company and the customer where the Company's pipeline facilities are connected with: (a) the facilities where the gas is being produced; or (b) with other facilities through which the gas is being transported. Deliveries to the Company in excess of the agreed upon quantities shall be grounds for termination of the contract by the Company.
- lii) Gas delivered to the Company shall be thermally evaluated at the point of receipt into the Company's system, and the Company will deliver to the customer gas with an equivalent British thermal unit (BTU) content based on: (a) the Company's calculated average BTU content; or (b) test results from a BTU sampler located at the point of redelivery to the customer.

(b) Pressure.

The Company shall not be required to alter its prevailing line pressure at the delivery point or at the redelivery point.

(c) Measurement.

- (i) When delivered to the customer, all gas shall be measured by the Company. The accuracy of meters used for that purpose shall be evaluated and maintained in accordance with the Michigan Public Service Commission Technical Standards For Gas Service (Technical Standards R460.2301).

Continued on Sheet No. E-8.00

Issued: January 2, 2008  
By J F Schott  
VP Regulatory Affairs  
Green Bay, Wisconsin

Effective for Service  
On and After: October 10, 2007

Issued Under Authority of  
Michigan Public Service Commission  
Dated: October 9, 2007  
In Case No: U-15152